



Product Service

CERTIFICATE

No. Z10 13 01 30906 003

Holder of Certificate: **WELLAND & TUXHORN AG**
Armaturen- und Maschinenfabrik
 Gütersloher Straße 257
 33649 Bielefeld
 GERMANY

Factory(ies): 30906

Certification Mark:



Product: **Valve**
1003 Safety Control Block

Model(s): **DDPE-PNEU-xxx-xxxx**
For nomenclature see attachment

Parameters:

Solenoid Voltage:	24V DC / 42V DC
Operating Pressure Range:	3...10bar
Environmental Temperature:	10°C...75°C
Safety Parameter:	SIL 2, Low Demand Mode

Tested according to:

- IEC 61508-1:1998 (SIL 2)
- IEC 61508-2:2000 (SIL 2)
- IEC 61508-4:1998 (SIL 2)
- IEC 61511-1:2004

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: WB84049T

Date, 2013-01-22 (Günter Greil)

Page 1 of 2

